



NOTES :  
\* CONCRETE TO TEST 4000 PSI @ 28 DAYS  
\* REFER TO CON ED DRAWINGS EO-12221-B & EO-13333-C FOR SPECIFIC DETAILS

(A) = SEE ELEVATION

Precast Manufacturing Co., LLC		
187 Strykers Road Phillipsburg, N.J. 08865		
Tel. (908) 454-2122 - Fax (908) 454-0512		
CONT.		
JOB		
CON ED DISTRIBUTION BOX TYPE DB-6 6'-0" x 4'-0" x 5'-0" ID		
DATE	DRAWN BY	DRAWING NO.
1 / 17	CLASSIC DESIGN	EO-13331 & 13333